

## Mississippi Annual Compliance Report Summary - 2019

Report Date: 06/18/2020 10:58:58

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Annual Compliance Report Date >= 01/01/2019 and Annual Compliance Report Date <= 12/31/2019 and Violation Codes not included in report (72, 76, 4A, 4B, 4C)

Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of Resolved Viols	# of PWS in Viols
04	MS	Maximum Contaminant Level Violation	Chemicals	Arsenic	3	0	1
04	MS	Maximum Contaminant Level Violation	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	40	7	16
04	MS	Maximum Contaminant Level Violation	Microbials	Revised Total Coliform Rule	1	0	1
<b>4</b>	<b>MS</b>	<b>Maximum Contaminant Level Violation</b>	<b>Sum</b>		<b>44</b>	<b>7</b>	<b>18</b>
04	MS	Monitoring Violation	Microbials	Revised Total Coliform Rule	55	48	50
04	MS	Monitoring Violation	Chemicals	Arsenic	14	0	10
<b>4</b>	<b>MS</b>	<b>Monitoring Violation</b>	<b>Sum</b>		<b>69</b>	<b>48</b>	<b>60</b>
04	MS	Monitoring and Reporting	Chemicals	Inorganic Chemicals	126	0	10
04	MS	Monitoring and Reporting	Chemicals	Lead and Copper Rule	31	7	28
04	MS	Monitoring and Reporting	Chemicals	Nitrates	79	0	19
04	MS	Monitoring and Reporting	Chemicals	Volatile Organic Chemicals	105	0	3
04	MS	Monitoring and Reporting	Disinfectants and Disinfection Byproducts Rule	Stage 1 Disinfectants and Disinfection Byproducts Rule	73	38	64
04	MS	Monitoring and Reporting	Disinfectants and Disinfection Byproducts Rule	Stage 2 Disinfectants and Disinfection Byproducts Rule	10	0	3
04	MS	Monitoring and Reporting	Microbials	Total Coliform Rule	1	0	1
<b>4</b>	<b>MS</b>	<b>Monitoring and Reporting</b>	<b>Sum</b>		<b>425</b>	<b>45</b>	<b>128</b>
04	MS	Other Violation	Other	Consumer Confidence Rule	32	29	32
04	MS	Other Violation	Other	Public Notice Rule	11	4	11
<b>4</b>	<b>MS</b>	<b>Other Violation</b>	<b>Sum</b>		<b>43</b>	<b>33</b>	<b>43</b>
04	MS	Treatment Technique Violation	Chemicals	Lead and Copper Rule	3	0	1
04	MS	Treatment Technique Violation	Microbials	Ground Water Rule	45	9	35
<b>4</b>	<b>MS</b>	<b>Treatment Technique Violation</b>	<b>Sum</b>		<b>48</b>	<b>9</b>	<b>36</b>

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period		Enforcement Action Type	RTC Date
							Begin Date	End Date		
MS0560014	ARLINGTON W/A-HINTONVILLE	Monitoring, Regular	MR	Nitrate-Nitrite	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0560014	ARLINGTON W/A-HINTONVILLE	Monitoring, Regular	MR	Nitrate	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0560014	ARLINGTON W/A-HINTONVILLE	Monitoring, Regular	MR	Nitrite	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0560014	ARLINGTON W/A-HINTONVILLE	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SOX	14-May-19
MS0560014	ARLINGTON W/A-HINTONVILLE	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0560006	ARLINGTON W/A	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SOX	14-May-19
MS0560006	ARLINGTON W/A	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0690021	INDEPENDENCE METHODIST CHURCH	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SIF	15-May-19
MS0120007	CITY OF QUITMAN	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Jan-17	31-Mar-17	SOX	12-Jun-17
MS0540001	ASL WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	03-Sep-19
MS0540001	ASL WATER ASSOCIATION	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SOX	28-Oct-19
MS0540001	ASL WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0240259	ST PATRICK HIGH SCHOOL	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-14		SIF	
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Notification, State	Other	TTHM	Known		01-Jul-18	30-Sep-18	SFJ	
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Oct-18	31-Dec-18	SIE	
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Notification, State	Other	Total Haloacetic Acids (HAA5)	Known		01-Oct-18	31-Dec-18	SFJ	
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jan-19	31-Mar-19	SFJ	
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	30-Jul-19
MS0630037	TRUELIGHT REDEVELOPMENT GRP #2	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Apr-19	30-Jun-19		
MS0230002	CITY OF WAVELAND	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Jul-19
MS0230002	CITY OF WAVELAND	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		14-Sep-16		SOX	05-Jun-18
MS0290009	TOMBIGBEE W/A	Monitoring and Reporting (DBP)	MR	TTHM	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SIF	18-Apr-19
MS0290009	TOMBIGBEE W/A	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SIF	18-Apr-19
MS0400005	LENA WATER ASSOCIATION	Notification, State	Other	Groundwater Rule	Returned to Compliance		01-Sep-13		SOX	01-Jul-14
MS0170018	CITY OF SOUTHAVEN	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	N	01-Oct-18	31-Dec-18	SOX	31-Mar-19
MS0320013	LORMAN WATER ASSOCIATION	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Dec-18		SOX	20-Aug-19
MS0320013	LORMAN WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jan-19	31-Mar-19	SIF	30-Jun-19
MS0320013	LORMAN WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	16-Jul-19
MS0610036	PRVWSD-PELAHATCHIE BAY	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Known	Y	01-Sep-19	30-Sep-19	SIE	
MS0060011	LAMONT WATER CORPORATION	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SIF	
MS0140008	TOWN OF JONESTOWN	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SOX	28-Oct-19
MS0140008	TOWN OF JONESTOWN	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,2,4-Trichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	cis-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Xylenes, Total	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	DICHLOROMETHANE	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	o-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	p-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Vinyl chloride	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,1-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	trans-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,2-Dichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,1,1-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Carbon tetrachloride	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,2-Dichloropropane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Trichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	1,1,2-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Tetrachloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	CHLOROETHYLENE	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Benzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Toluene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Ethylbenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0140008	TOWN OF JONESTOWN	Monitoring, Regular	MR	Styrene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0300147	NAVAL STATION-PASCAGOULA	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SIF	08-May-19
MS0300147	NAVAL STATION-PASCAGOULA	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0300147	NAVAL STATION-PASCAGOULA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Apr-19	30-Jun-19	SFR	
MS0300147	NAVAL STATION-PASCAGOULA	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Jul-19	30-Sep-19	SIE	
MS0300147	NAVAL STATION-PASCAGOULA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jul-19	30-Sep-19	SIE	
MS0300014	JACKSON CO WEST PORT AUTH.	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SIF	08-May-19

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period Begin Date	Compliance Period End Date	Enforcement Action Type Code	RTC Date
MS0300013	JACKSON CO. E PORT AUTHORITY	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SIF	08-May-19
MS0300013	JACKSON CO. E PORT AUTHORITY	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0510011	CITY OF UNION	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Aug-19		SFR	
MS0450008	TOWN OF FLORA #1	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Jan-18	31-Dec-18	SIF	
MS0450008	TOWN OF FLORA #1	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Jan-18	31-Dec-18	SIF	
MS0360068	DELTA RAIN - WELLSGATE	Failure To Address Deficiency	TT	Groundwater Rule	Open		13-Sep-13		SFR	
MS0050017	NORTH BENTON W/A	Maximum Contaminant Level Violation, Average	MCL	Arsenic	Known		01-Jan-18	31-Mar-18	SO8	
MS0050017	NORTH BENTON W/A	Maximum Contaminant Level Violation, Average	MCL	Arsenic	Known		01-Oct-18	31-Dec-18	SO8	
MS0050017	NORTH BENTON W/A	Maximum Contaminant Level Violation, Average	MCL	Arsenic	Known		01-Jan-19	31-Mar-19	SO8	
MS0050017	NORTH BENTON W/A	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Mar-19	31-Mar-19	SOX	16-Apr-19
MS0050017	NORTH BENTON W/A	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jan-19	31-Mar-19	SOX	30-Jun-19
MS0050017	NORTH BENTON W/A	Maximum Contaminant Level Violation, Average	MCL	Arsenic	Known		01-Apr-19	30-Jun-19	SIF	
MS0050017	NORTH BENTON W/A	Maximum Contaminant Level Violation, Average	MCL	Arsenic	Known		01-Jul-19	30-Sep-19	SIF	
MS0140005	TOWN OF LULA	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	12-Aug-19
MS0220002	G T & Y WATER DISTRICT INC	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Oct-18	31-Dec-18	SIF	
MS0220002	G T & Y WATER DISTRICT INC	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jan-19	31-Mar-19	SIF	
MS0220002	G T & Y WATER DISTRICT INC	Public Notification Violation for NPDWR Violation	Other	Public Notice	Returned to Compliance		13-Jun-19		SOX	17-Jun-19
MS0220002	G T & Y WATER DISTRICT INC	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Apr-19	30-Jun-19	SIF	
MS0220002	G T & Y WATER DISTRICT INC	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jul-19	30-Sep-19	SFJ	
MS0820027	MIDWAY W/A #2	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0820027	MIDWAY W/A #2	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0740059	LEES CHAPEL CHURCH	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Nov-18	30-Nov-18	SIF	10-Dec-18
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	CYANIDE	Known	Y	01-Jan-16	31-Dec-18	SFJ	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Feb-19	28-Feb-19	SOX	25-Mar-19
MS0250021	REEDTOWN WATER ASSN	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jan-19	31-Mar-19	SOX	30-Jun-19
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2,4-Trichlorobenzene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	cis-1,2-Dichloroethylene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Xylenes, Total	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	DICHLOROMETHANE	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	o-Dichlorobenzene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	p-Dichlorobenzene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Vinyl chloride	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1-Dichloroethylene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	trans-1,2-Dichloroethylene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2-Dichloroethane	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1,1-Trichloroethane	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Carbon tetrachloride	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2-Dichloropropane	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Trichloroethylene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1,2-Trichloroethane	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Tetrachloroethylene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	CHLOROBENZENE	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Benzene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Toluene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Ethylbenzene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Styrene	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2,4-Trichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	cis-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Xylenes, Total	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	DICHLOROMETHANE	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	o-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	p-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Vinyl chloride	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	trans-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2-Dichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1,1-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Carbon tetrachloride	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,2-Dichloropropane	Known	Y	01-Jul-19	30-Sep-19	SIE	

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period Begin Date	Compliance Period End Date	Enforcement Action Type Code	RTC Date
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Trichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	1,1,2-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Tetrachloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	CHLOROBENZENE	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Benzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Toluene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Ethylbenzene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0250021	REEDTOWN WATER ASSN	Monitoring, Regular	MR	Styrene	Known	Y	01-Jul-19	30-Sep-19	SIE	
MS0060006	CITY OF CLEVELAND	Follow-up Or Routine LCR Tap M/R	MR	Lead and Copper Rule	Open		01-Jan-19		SFJ	
MS0140003	TOWN OF COAHOMA	Notification, State	Other	TTHM	Known		01-Oct-18	31-Dec-18	SFR	
MS0140003	TOWN OF COAHOMA	Notification, State	Other	Total Haloacetic Acids (HAA5)	Known		01-Oct-18	31-Dec-18	SFR	
MS0140003	TOWN OF COAHOMA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Oct-18	31-Dec-18	SFR	
MS0140003	TOWN OF COAHOMA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jan-19	31-Mar-19	SFR	
MS0140003	TOWN OF COAHOMA	Public Notification Violation for NPDWR Violation	Other	Public Notice	Open		08-Jun-19			
MS0140003	TOWN OF COAHOMA	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		08-Apr-13		SOX	05-Feb-18
MS0410011	TOWN OF PLANTERSVILLE	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	18-Jul-19
MS0130019	GOLDEN TRIANGLE W/A #2	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0130019	GOLDEN TRIANGLE W/A #2	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0570048	ST MARY OF THE PINES	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	04-Sep-19
MS0530001	ADATON W/A #1-JOSEY CREEK	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SIF	23-Oct-19
MS0530001	ADATON W/A #1-JOSEY CREEK	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0540011	INDEPENDENCE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0540072	NORTH PANOLA WATER DISTRICT	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jan-19	31-Mar-19	SFJ	
MS0360069	TWELVE OAKS WATER SYSTEM	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	10-Jul-19
MS0360069	TWELVE OAKS WATER SYSTEM	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Sep-16		SIF	15-Aug-18
MS0330002	CARSON CENTRAL WATER ASSN	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Oct-15		SIF	24-Nov-15
MS0540032	PLUM POINT COMMUNITY WATER ASSN	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-16		SFR	
MS0250008	CITY OF JACKSON	WQP Entry Point/Tap Treatment Technique Non-Compliance	TT	Lead and Copper Rule	Known		01-Jan-19	30-Jun-19	SIF	
MS0250008	CITY OF JACKSON	WQP Entry Point/Tap Treatment Technique Non-Compliance	TT	Lead and Copper Rule	Known		01-Jul-19	31-Dec-19	SFJ	
MS0210012	S E GREENE WATER AUTHORITY	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Jun-19	30-Jun-19	SIF	17-Jul-19
MS0210012	S E GREENE WATER AUTHORITY	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0680012	TOWN OF WEBB	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Aug-19
MS0240089	TUXACHANIE ESTATES #2	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jun-19	30-Jun-19	SFJ	01-Jul-19
MS0240089	TUXACHANIE ESTATES #2	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0240089	TUXACHANIE ESTATES #2	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Sep-13		SIF	20-Feb-19
MS0250005	TOWN OF EDWARDS	Maximum Contaminant Level Violation, Single Sample	MCL	Gross Alpha, Incl. Radon and U	Known		01-Jan-10	31-Dec-18	SIF	
MS0250005	TOWN OF EDWARDS	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jan-19	31-Mar-19	SIF	
MS0670004	CITY OF DREW	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jul-12		SOX	31-Aug-12
MS0530022	TALKING WARRIOR WATER ASSN #1	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Jul-19
MS0530023	TRIMCANE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	09-Dec-19
MS0530023	TRIMCANE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	TTHM	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	09-Dec-19
MS0490016	HAYS CREEK W/A-MINERVA	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jan-12		SOX	29-Apr-15
MS0270007	TOWN OF SILVER CITY	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SFR	
MS0280001	TOWN OF MAYERSVILLE	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Jul-15		SFR	
MS0580002	EAST PONTOTOC WATER ASSN	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0540015	PANOLA-UNION W/A	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	10-Jul-19
MS0230065	HANCOCK COUNTY WATER & SEWER	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Oct-18	31-Dec-18	SOX	12-Nov-19
MS0230065	HANCOCK COUNTY WATER & SEWER	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Jan-19	31-Mar-19	SOX	12-Nov-19
MS0230065	HANCOCK COUNTY WATER & SEWER	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Apr-19	30-Jun-19	SOX	12-Nov-19
MS0440013	NEW VISION MOBILE HOME PARK	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Apr-13		SOX	25-Jun-15
MS0250022	SOUTH CENTRAL WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Jan-19	31-Mar-19	SFR	
MS0250022	SOUTH CENTRAL WATER ASSN	Public Notification Violation for NPDWR Violation	Other	Public Notice	Returned to Compliance		08-Jun-19		SOX	26-Jun-19
MS0250022	SOUTH CENTRAL WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Apr-19	30-Jun-19	SFR	
MS0250022	SOUTH CENTRAL WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Apr-19	30-Jun-19	SFR	
MS0250022	SOUTH CENTRAL WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Jul-19	30-Sep-19	SFR	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Antimony, Total	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Chromium	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Cadmium	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Thallium, Total	Known	Y	01-Jan-16	31-Dec-18	SIE	

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period		Enforcement Action Type	RTC Date
							Begin Date	End Date		
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Beryllium, Total	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Selenium	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Mercury	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Regular	MR	Arsenic	Known	Y	01-Jan-16	31-Dec-18	SIE	
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SOX	23-Oct-19
MS0530039	NEW LIGHT WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0150011	TOWN OF WESSON	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jun-19	30-Jun-19	SOX	18-Jul-19
MS0150011	TOWN OF WESSON	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0320015	MCNAIR-STAMPLEY W/A #3	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Dec-18		SOX	18-Mar-19
MS0320010	MCNAIR-STAMPLEY W/A #2	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Dec-18		SOX	18-Mar-19
MS0320003	MCNAIR-STAMPLEY W/A #1	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Dec-18		SOX	18-Mar-19
MS0320003	MCNAIR-STAMPLEY W/A #1	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jun-11		SOX	19-Nov-13
MS0690002	TOWN OF COLDWATER	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	27-Sep-19
MS0260016	TOWN OF TCHULA	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jun-19	30-Jun-19	SIF	08-Jul-19
MS0260016	TOWN OF TCHULA	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0440004	TOWN OF CRAWFORD	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Jul-19	31-Jul-19	SOX	14-Aug-19
MS0440004	TOWN OF CRAWFORD	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0050002	TOWN OF HICKORY FLAT	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Mar-19	31-Mar-19	SIF	15-Apr-19
MS0050002	TOWN OF HICKORY FLAT	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jan-19	31-Mar-19	SIF	
MS0050002	TOWN OF HICKORY FLAT	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jul-19	31-Jul-19	SOX	09-Sep-19
MS0050002	TOWN OF HICKORY FLAT	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0050002	TOWN OF HICKORY FLAT	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	08-Aug-19
MS0270001	CITY OF BELZONI	Follow-up Or Routine LCR Tap M/R	MR	Lead and Copper Rule	Returned to Compliance		01-Jan-19		SIE	31-Dec-18
MS0230001	CITY OF BAY ST LOUIS	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	N	01-Oct-18	31-Dec-18	SOX	31-Mar-19
MS0410038	BURLESON MOBILE HOME PARK	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Nov-18	30-Nov-18	SIF	17-Dec-18
MS0410038	BURLESON MOBILE HOME PARK	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Oct-18	31-Dec-18	SOX	31-Mar-19
MS0410038	BURLESON MOBILE HOME PARK	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Oct-17		SIF	26-Feb-18
MS0120012	CLARKCO STATE PARK	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0520027	SUPERIOR FISH PRODUCTS	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jan-19	31-Jan-19	SIF	12-Feb-19
MS0520027	SUPERIOR FISH PRODUCTS	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jan-19	31-Mar-19	SIF	
MS0680013	WEST TALLAHATCHIE UTL ASSN	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Jul-19
MS0690004	LOOXAHOMA WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	20-Aug-19
MS0700008	CITY OF RIPLEY	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Apr-19	30-Apr-19	SIF	28-May-19
MS0700008	CITY OF RIPLEY	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0740004	LEXIE WATER ASSOCIATION, INC.	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Apr-19	30-Apr-19	SIF	06-May-19
MS0740004	LEXIE WATER ASSOCIATION, INC.	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0710011	WALKER SWITCH WATER ASSN	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jul-19	31-Jul-19	SOX	13-Aug-19
MS0710011	WALKER SWITCH WATER ASSN	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0060042	SYMONDS WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	12-Aug-19
MS0060042	SYMONDS WATER ASSOCIATION	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		21-Nov-14		SOX	27-Feb-19
MS0060003	TOWN OF BEULAH	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	07-Aug-19
MS0680008	PAYNES WATER ASSOCIATION	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-May-19	31-May-19	SOX	27-Jun-19
MS0680008	PAYNES WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	13-Nov-19
MS0610086	THOMASVILLE W/A #2	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0610029	THOMASVILLE W/A #1	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0760076	BLACK BAYOU WATER ASSN.	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0300064	COLONIAL ESTATES # 3	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SFR	
MS0810005	JEFF DAVIS W/A INC	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	01-Aug-19
MS0470109	DOLLAR GENERAL #19963	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Mar-19		SOX	06-Jun-19
MS0220040	HUGH WHITE STATE PARK	Monitoring, Regular	MR	Nitrate-Nitrite	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0220040	HUGH WHITE STATE PARK	Monitoring, Regular	MR	Nitrate	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0220040	HUGH WHITE STATE PARK	Monitoring, Regular	MR	Nitrite	Known	Y	01-Jan-18	31-Dec-18	SIE	
MS0600009	NORFLEET UTILITIES, INC	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	29-Jul-19
MS0270003	TOWN OF ISOLA	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Jan-12		SFR	
MS0470069	SOUTH VICTORIA	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	05-Sep-19
MS0470069	SOUTH VICTORIA	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Sep-13		SOX	25-Jun-15
MS0240281	LYMAN MDOT	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SOX	09-Oct-19
MS0090023	CCM WATER ASSOCIATION	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jul-12		SOX	09-Sep-19
MS0570004	CITY OF MCCOMB	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Jun-19	30-Jun-19	SIF	23-Jul-19

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period Begin Date	Compliance Period End Date	Enforcement Action Type Code	RTC Date
MS0570004	CITY OF MCCOMB	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0570004	CITY OF MCCOMB	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		17-Jul-19		SOX	21-Aug-19
MS0480005	VILLAGE OF GATTMAN	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Nov-11		SOX	28-Feb-12
MS0300079	BLUFF CREEK MOBILE HOME PARK	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SFR	
MS0300079	BLUFF CREEK MOBILE HOME PARK	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Oct-15		SFN	
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrate-Nitrite	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrate	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrite	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrate-Nitrite	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrate	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0060054	NORTH BOLIVAR W/A	Monitoring, Regular	MR	Nitrite	Returned to Compliance	Y	01-Jan-18	31-Dec-18	SOX	30-Jan-19
MS0250026	TOWN OF UTICA	Follow-up Or Routine LCR Tap M/R	MR	Lead and Copper Rule	Open		01-Jul-19		SIE	
MS0250026	TOWN OF UTICA	Follow-up Or Routine LCR Tap M/R	MR	Lead and Copper Rule	Open		01-Jan-19		SFJ	
MS0040005	MCADAMS WATER ASSOCIATION	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-11		SIE	
MS0260043	HARLAND CREEK W/A-HORSESHOE LK	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jul-19	31-Jul-19	SIF	05-Aug-19
MS0260043	HARLAND CREEK W/A-HORSESHOE LK	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0140053	COAHOMA UTILITY DIST #2	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Oct-18	31-Dec-18	SIE	
MS0140053	COAHOMA UTILITY DIST #2	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jan-19	31-Mar-19	SFR	
MS0140053	COAHOMA UTILITY DIST #2	Public Notification Violation for NPDWR Violation	Other	Public Notice	Returned to Compliance		07-Jun-19		SOX	07-Jun-19
MS0140053	COAHOMA UTILITY DIST #2	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Apr-19	30-Jun-19	SIF	
MS0140053	COAHOMA UTILITY DIST #2	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jul-19	30-Sep-19	SIF	
MS0710006	CITY OF IUKA	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	N	01-Nov-18	30-Nov-18	SIF	18-Dec-18
MS0710006	CITY OF IUKA	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Oct-18	31-Dec-18	SOX	31-Mar-19
MS0780003	CUMBERLAND WATER ASSN #1	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Sep-19	30-Sep-19	SOX	30-Oct-19
MS0780003	CUMBERLAND WATER ASSN #1	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0240256	THE OAKS UTILITIES	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jan-19	31-Jan-19	SIF	13-Feb-19
MS0240256	THE OAKS UTILITIES	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jan-19	31-Mar-19	SOX	30-Jun-19
MS0240256	THE OAKS UTILITIES	Failure To Address Deficiency	TT	Groundwater Rule	Open		13-Sep-13		SIF	
MS0410026	TOMBIGBEE STATE PARK	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jul-15		SIF	20-Mar-17
MS0150007	TOWN OF HAZLEHURST	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Aug-19	31-Aug-19	SIF	10-Sep-19
MS0150007	TOWN OF HAZLEHURST	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0240195	PINE HAVEN MOBILE HOME VILLAGE	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SIF	
MS0760005	CITY OF HOLLANDALE	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Dec-18		SIF	12-Mar-19
MS0250001	TOWN OF BOLTON	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jun-12		SOX	09-Jul-15
MS0140012	MOORE BAYOU WATER ASSOCIATION	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Aug-19	31-Aug-19	SOX	16-Sep-19
MS0140012	MOORE BAYOU WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0300168	THE OAKS OF MOSS POINT	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-May-19	31-May-19	SOX	18-Jun-19
MS0300168	THE OAKS OF MOSS POINT	Public Notification Violation for NPDWR Violation	Other	Public Notice	Open		01-May-19		SIE	
MS0770005	HIWANNEE WATER ASSOCIATION #1	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Oct-18	31-Dec-18	SOX	11-Jun-19
MS0770005	HIWANNEE WATER ASSOCIATION #1	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Jan-19	31-Mar-19	SIF	11-Jun-19
MS0770005	HIWANNEE WATER ASSOCIATION #1	Public Notification Violation for NPDWR Violation	Other	Public Notice	Returned to Compliance		08-Jun-19		SOX	12-Jun-19
MS0110005	TOWN OF PORT GIBSON	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Jun-18		SIF	27-Aug-18
MS0110005	TOWN OF PORT GIBSON	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Feb-11		SIB	
MS0110005	TOWN OF PORT GIBSON	Failure To Address Deficiency	TT	Groundwater Rule	Open		01-Sep-13		SIB	
MS0110003	HERMANVILLE WATER ASSOCIATION	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Returned to Compliance		01-Oct-18	31-Dec-18	SIF	01-Mar-19
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Apr-19	30-Jun-19	SIE	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2,4-Trichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	cis-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Xylenes, Total	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	DICHLOROMETHANE	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	o-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	p-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Vinyl chloride	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	trans-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2-Dichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	

# Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period Begin Date	Compliance Period End Date	Enforcement Action Type Code	RTC Date
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1,1-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Carbon tetrachloride	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2-Dichloropropane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Trichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1,2-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Tetrachloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	CHLOROBENZENE	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Benzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Toluene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Ethylbenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Styrene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2,4-Trichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	cis-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Xylenes, Total	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	DICHLOROMETHANE	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	o-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	p-Dichlorobenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Vinyl chloride	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	trans-1,2-Dichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2-Dichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1,1-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Carbon tetrachloride	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,2-Dichloropropane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Trichloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	1,1,2-Trichloroethane	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Tetrachloroethylene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	CHLOROBENZENE	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Benzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Toluene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Ethylbenzene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0110003	HERMANVILLE WATER ASSOCIATION	Monitoring, Regular	MR	Styrene	Known	Y	01-Jul-19	30-Sep-19	SIF	
MS0300170	MIDWAY FOOD MART	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jun-19	30-Jun-19	SOX	31-Jul-19
MS0670014	MS STATE PENITENTIARY-MN LN	Monitoring and Reporting (DBP)	MR	Total Haloacetic Acids (HAA5)	Known	Y	01-Jan-18	31-Dec-18	SIF	
MS0670014	MS STATE PENITENTIARY-MN LN	Monitoring and Reporting (DBP)	MR	TTHM	Known	Y	01-Jan-18	31-Dec-18	SIF	
MS0530044	EAST LEE BLVD WATER ASSN.	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	30-Jul-19
MS0530044	EAST LEE BLVD WATER ASSN.	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Aug-19	31-Aug-19	SOX	25-Sep-19
MS0530044	EAST LEE BLVD WATER ASSN.	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jul-19	30-Sep-19	SOX	31-Dec-19
MS0670003	TOWN OF DODDSVILLE	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Returned to Compliance		01-Oct-18	31-Dec-18	SOX	13-Mar-19
MS0670003	TOWN OF DODDSVILLE	Notification, State	Other	Total Haloacetic Acids (HAA5)	Known		01-Oct-18	31-Dec-18	SFJ	
MS0670003	TOWN OF DODDSVILLE	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	01-Aug-19
MS0670003	TOWN OF DODDSVILLE	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Feb-13		SIF	12-Jul-19
MS0670003	TOWN OF DODDSVILLE	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Jul-19	30-Sep-19	SIE	
MS0670003	TOWN OF DODDSVILLE	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jul-19	30-Sep-19		
MS0570052	DOLLAR GENERAL #19879	Reporting, Assessment Forms (RTCR)	RPT	Revised Total Coliform Rule	Returned to Compliance		01-Jun-19		SOX	02-Aug-19
MS0170005	DAYS WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Known	Y	01-Jan-19	31-Mar-19	SIF	
MS0170005	DAYS WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0170005	DAYS WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	07-Aug-19
MS0080006	TOWN OF NORTH CARROLLTON	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		05-Dec-11		SOX	08-Dec-14
MS0690012	SENATOBIA LAKES ESTATES, INC	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Oct-12		SOX	25-Apr-19
MS0140052	MOORE BAYOU W/A #3	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Jan-19	31-Mar-19	SIF	15-May-19
MS0560002	TOWN OF NEW AUGUSTA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Jan-19	31-Mar-19	SOX	13-Nov-19
MS0560002	TOWN OF NEW AUGUSTA	Maximum Contaminant Level Violation, Average	MCL	TTHM	Returned to Compliance		01-Apr-19	30-Jun-19	SOX	13-Nov-19
MS0420035	MINTER CITY WATER & SEWER	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Oct-18	31-Dec-18	SIF	31-Mar-19
MS0610022	CLEARY WATER SEWER & FIRE DEPT	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0610022	CLEARY WATER SEWER & FIRE DEPT	Maximum Contaminant Level Violation, Average	MCL	TTHM	Known		01-Jul-19	30-Sep-19	SIE	
MS0590018	NEW SITE WATER ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	18-Jul-19
MS0360011	CITY OF OXFORD	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	N	01-Apr-19	30-Jun-19	SOX	30-Sep-19
MS0670006	CITY OF INDIANOLA	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	03-Sep-19

## Mississippi Public Water Supply Violation Report 2019

Report Date: 06/18/2020 12:17:25

Report Filters: Submission Year is 2020 and Quarter is 1 and EPA Region is National and Primacy Agency in (MS) and Violation First Reported Date >= 01/01/2019 and Violation First Reported Date <= 12/31/2019

PWS ID	PWS Name	Violation Type	Violation Category Code	Contaminant Name	Compliance Status	Is Major Violation	Compliance Period Begin Date	Compliance Period End Date	Enforcement Action Type Code	RTC Date
MS0170006	EUDORA UTILITIES ASSOCIATION	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Aug-19
MS0600012	SOUTH LAKE WATER ASSOCIATION	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Nov-18	30-Nov-18	SIF	12-Dec-18
MS0600012	SOUTH LAKE WATER ASSOCIATION	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Oct-18	31-Dec-18	SOX	31-Mar-19
MS0620007	L & F WATER ASSOCIATION	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Apr-13		SOX	22-May-13
MS0620007	L & F WATER ASSOCIATION	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Known		01-Apr-19	30-Jun-19	SIF	
MS0730010	LAKE ARROWHEAD	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	25-Jul-19
MS0170033	KOKO REEF WATER CO	Monitoring, Routine (RTCR)	MON	Revised Total Coliform Rule	Returned to Compliance	Y	01-Jan-19	31-Jan-19	SOX	27-Feb-19
MS0170033	KOKO REEF WATER CO	Monitoring and Reporting (DBP)	MR	Chlorine	Returned to Compliance	Y	01-Jan-19	31-Mar-19	SOX	30-Jun-19
MS0170033	KOKO REEF WATER CO	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	09-Aug-19
MS0240038	CEDAR LAKE APARTMENTS	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		13-Sep-13		SOX	29-May-19
MS0240213	COUNTRY LIVING MOBILE HOME PK	Failure To Address Deficiency	TT	Groundwater Rule	System Inactive		01-Sep-13		SIB	28-Feb-20
MS0370018	BILLS TRAILER PARK	Failure To Address Deficiency	TT	Groundwater Rule	Returned to Compliance		01-Jul-15		SOX	22-Jul-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Notification, State	Other	TTHM	Returned to Compliance		01-Jul-18	30-Sep-18	SOX	11-Jun-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	Returned to Compliance		01-Oct-18	31-Dec-18	SOX	11-Jun-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	System Inactive		01-Oct-18	31-Dec-18	SIE	07-Oct-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Notification, State	Other	Total Haloacetic Acids (HAA5)	Returned to Compliance		01-Oct-18	31-Dec-18	SOX	11-Jun-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Public Notification Violation for NPDWR Violation	Other	Public Notice	System Inactive		23-Mar-19			07-Oct-19
MS0630007	TRUELIGHT REDEVELOPMENT GROUP	Consumer Confidence Report Complete Failure to Report	Other	Consumer Confidence Rule	Returned to Compliance		01-Jul-19		SOX	30-Jul-19
MS0760075	DARLOVE-MURPHY WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	System Inactive		01-Oct-18	31-Dec-18	SIF	30-Sep-19
MS0760075	DARLOVE-MURPHY WATER ASSN	Maximum Contaminant Level Violation, Average	MCL	Total Haloacetic Acids (HAA5)	System Inactive		01-Jan-19	31-Mar-19	SIF	30-Sep-19